



Akciju sabiedrība „Latvenergo”

Vien. reg. Nr. 40003032949

Pulkveža Brieža iela 12, Rīga, LV-1230, Latvija

Tālr. (+371) 67728222,

www.latvenergo.lv, info@latvenergo.lv

Rīgā

#REG-DATE# Nr. #REG-NUMBER#

Potenciālajiem kandidātiem /
Potential applicants

Par nolikuma skaidrošanu/ On clarification of regulations (skaidrojums/clarification Nr.2)

Saskaņā ar sarunu nolikuma - "2x250MVA sprieguma paaugstinošo transformatoru piegāde Rīgas HES" (ID Nr.IPR-67154) nolikuma 5.16. punktu sniedzam atbildi uz saņemtajiem jautājumiem:

1.jautājums: Vai divu 250MVA sprieguma paaugstinošo transformatoru piegādes apjomā ietilpst piegādāto transformatoru montāžas un takelāžas darbi vai tikai montāžas darbu uzraudzība?

Atbilde: Divu 250MVA sprieguma paaugstinošo transformatoru piegādes apjomā ietilpst piegādāto transformatoru transportēšana līdz pagaidu uzglabāšanas vietai, nokraušana no kravas platformas, montāžas darbu uzraudzība, iereģulēšana.

2.jautājums: Vai jaunpiegādāto transformatoru novietošanas vieta būs to montāžas vieta uz vecajiem esošajiem pamatiem vai tiks norādīta cita novietošanas vieta?

Atbilde: Jaunpiegādāto transformatoru pagaidu novietošanas vieta būs uzglabāšanas laukums pie Rīgas HES. Jaunpiegādāto transformatoru montāžas vieta būs uz esošajiem, atbilstoši sagatavotajiem pamatiem (sliedes).

3.jautājums: Kāda ir paredzamā transformatoru piegādes adrese? Vai tas ir pa tiešo uz Rīgas HES, vai arī tos iepriekš paredzēts novietot Pasūtītāja norādītajā vietā?

Atbilde: Transformatoru piegādes adrese ir Rīgas HES Doles sala. Transformatorus pēc piegādes paredzēts novietot Pasūtītāja norādītajā vietā.

4.jautājums: Kas veic esošo transformatoru demontāžu?

Atbilde: Esošo transformatoru demontāžu veic cits uzņēmējs atsevišķa iepirkuma ietvaros.

5.jautājums: Vai darbu apjomā ir iekļauta tikai uzstādīšanas uzraudzība, vai arī ir jaiekļauj jauno transformatoru uzstādīšana (takelāža) uz pamatiem?

Atbilde: Skat. atbildi uz 1.jautājumu.

6.jautājums: Gadījumā, ja jaunie transformatori ir jāuzstāda uz pamatiem, tad ņemot vērā, kad tie atrodas ļoti tuvu E67 šosejai, vai ir paredzēta iespēja slēgt ceļu montāžas darbu veikšanai?

Atbilde: Jaunu transformatoru uzstādīšanu uz pamatiem veic uzņēmējs cita iepirkuma ietvaros.

In compliance with the Regulations of negotiation announced by AS "Latvenergo" "The supply of 2x250MVA generator step-up transformers for Riga HPP" (ID No.IPR-67154) Clause 5.16 we are responding to the received questions:

Question 1: Please clarify if 250 MVA transformer supply scope includes installation of supplied transformers and lifting works or only supervision of the installation?

Answer: 250 MVA transformer supply scope includes transformers transportation to temporary storage place, unloading, supervision of assembling, commissioning.

Question 2: Please clarify if new transformer installation place will be installation place on old existing foundations or other installation place will be indicated?

Answer: New transformer temporary storage place will be storage area near RHPP. New transformer installation place will be on existing appropriately prepared foundations (rails).

Question 3: What is the address of the supply? The supply shall be done directly to RHPP or supplies shall be done to the place indicated by the Employer?

Answer: Transformers supply address will be Rīgas HPP, island of Dole. The transformers shall be unloaded to the place, indicated by the Employer.

Question 4: Who will perform dismantling of the existing transformer?

Answer: Dismantling of the existing transformers will be performed as part of other procurement.

Question 5: Please clarify if scope of work includes only installation supervision or it also includes installation of new transformer on foundations (lifting)?

Answer: See answer to Question 1.

Question 6: in the event if installation of transformer on foundations is included, taking into account that these are located near road E67 please clarify if possibility to close this road is foreseen for installation works?

Answer: Installation of new transformers will be performed as part of other procurement.

Šis dokuments ir parakstīts ar drošu elektronisko parakstu un satur laika zīmogu.

Projektu vadītājs

Aigars Greitāns

Aigars Greitāns 67728270, 29431215